



SOLVAY
MINERALS

January 24, 2002



Dan Olson
WDEQ-Air Quality Division
122 W. 25th Street
Cheyenne, WY 82002

RE: Submittal of Compliance Stack Test Results for AQD #76

Dear Dan:

Enclosed you will find Stack Test Report No. SOL1596 and certification by Ronald O. Hughes, Resident Manager. The testing was conducted by Air Pollution Testing, Inc. on AQD #76, the Primary Crusher Baghouse Stack, on December 12 and 13, 2001. AQD #76 was permitted under CT-1347, issued February 6, 1998, with testing requirements detailed in condition (F8) of Operating Permit 30-126 issued July 24, 2001.

EPA Reference Method 5 with 202 back half inorganic was utilized, as required, to determine particulate emissions. Test results show compliance at 0.93 pph, compared to the permit limit of 2.45 pph.

If you have any questions concerning the test results, feel free to contact me at (307) 872-6571.

Respectfully submitted,

Dolly A. Potter
Environmental Services Supervisor

Cc: Tony Hoyt

Enclosures

